# Safety Stations with Eyewash



## **G1991-316** Safety Station with Eyewash, Type 316 All-Stainless Steel Construction

Application: All-stainless steel combination eyewash and shower safety station. Unit is constructed in Type 316 stainless steel for superior corrosion resistance, making it ideal for use in highly corrosive environments, cleanrooms, and washdown applications. Eyewash features two GS-Plus™ spray-type outlet heads that deliver a flood of water for rinsing eyes.

Shower Head: 10" diameter stainless steel with 20 GPM flow control.

Shower Valve: 1" IPS Type 316 stainless steel stay-open ball valve. Valve has stainless steel ball and PTFE seals. Furnished with stainless steel actuating arm and 29" stainless steel pull rod.

**Spray Head Assembly:** Two GS-Plus<sup>™</sup> spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from water flow.

Eyewash Bowl: 11-1/8" diameter stainless steel.

Eyewash Valve: 1/2" IPS Type 316 stainless steel stay-open ball valve. Valve has stainless steel ball and PTFE seals.

**Pipe and Fittings:** Schedule 40 Type 316 brushed stainless steel. Furnished with orange polyethylene pipe covers for high visibility and corrosion resistance.

Supply: 1-1/4" NPT female top or side inlet.

Waste: 1-1/4" NPT female outlet. Outlet can be positioned at either 8-1/4" or 19-3/8" above finished floor by reversing lower pipe nipples.

Sign: ANSI-compliant identification sign.

Quality Assurance: Valve and spray head assemblies are factory assembled and water tested prior to shipment.

#### **Available Options**

- **G6040** Thermostatic mixing valve precisely blends hot and cold water to deliver tepid water as required by ANSI Z358.1-2014. Refer to "Thermostatic Mixing Valves" section for complete technical and product selection information.
- BC Stainless steel cover for eyewash bowl.
- AP275-200 Electric flashing light and alarm horn unit for mounting on wall or vertical pipe. Light illuminates and horn sounds when eyewash or shower is activated. Furnished complete with flow switch and mounting hardware.

**AP250-015** Modesty curtain for mounting on safety station.






312 447 8100 TELEPHONE gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

## Safety Stations with Eyewash



## **G1991-316** Safety Station with Eyewash, Type 316 All-Stainless Steel Construction



Guardian Equipment 1140 N North Branch St Chicago, IL 60642 312 447 8100 TELEPHONE 312 447 8101 FACSIMILE gesafety.com Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

